

2430 "E" Street, N. W.
Washington, D. C.
9 December 1953

25X1A9a



25X1A9a

Dear Mr. [REDACTED]:

Reference is made to your letter of 2 December 1953 on the subject of a proposal for changing cattle guards.

The information sent to you in answer to your teletype requesting verification of the spacing for the pipe was obtained from the Bureau of Agriculture by phone. This now appears to be incorrect. After checking their official Farmers' Bulletin No. 1584, it has been determined that the cattle guard as originally designed and dimensioned on the contract drawings, meets the requirement of the Bureau of Agriculture and no change is desired on the guard that has been completed.

The cattle guard at the main entrance from the county road may be constructed in accordance with the 5" o.c. pipe spacing since the forms and frames have been changed to accommodate the new spacing.

Very truly yours,

25X1A9a

